



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C
L
I
E
N
T
Newberg School District
Attn: Scott Woods
714 E 6th St.
Newberg OR, 97132
Phone: (503) 554-5024

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-01	Sample Name: B Hallway fountain - large Sampled: 6/28/16 5:30						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-02	Sample Name: B Hallway fountain - small Sampled: 6/28/16 5:30						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-03	Sample Name: A Hallway fountain - short Sampled: 6/28/16 5:35						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-04	Sample Name: A Hallway fountain - tall Sampled: 6/28/16 5:35						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-05	Sample Name: D Hallway fountain - short Sampled: 6/28/16 5:45						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-06	Sample Name: D Hallway fountain - tall Sampled: 6/28/16 5:45						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-07	Sample Name: Main Kitchen East Sink Sampled: 6/28/16 5:50						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-08	Sample Name: Main Kitchen North Sink Sampled: 6/28/16 5:50						Matrix: Water
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	08/15/16 16:05
6183007-09	Sample Name: Main Kitchen East Hand Sink Sampled: 6/28/16 5:55						Matrix: Water
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	08/15/16 16:05
6183007-10	Sample Name: Middle Kitchen South Sink Sampled: 6/28/16 6:00						Matrix: Water
+Lead	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	08/15/16 16:05



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-11	Sample Name: West Commons South Sink Sampled: 6/28/16 6:15						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-12	Sample Name: Healthroom Sink Sampled: 6/28/16 6:15						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-13	Sample Name: Main office Workroom Sampled: 6/28/16 6:20						Matrix: Water
+Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	08/15/16 16:05
6183007-14	Sample Name: Section B Clayroom west sink Sampled: 6/28/16 6:30						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-15	Sample Name: E Hallway tall fountain Sampled: 6/28/16 6:35						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-16	Sample Name: E Hallway short fountain Sampled: 6/28/16 6:35						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-17	Sample Name: F Hallway short fountain Sampled: 6/28/16 6:50						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-18	Sample Name: F 103 Front East Sink Sampled: 6/28/16 6:50						Matrix: Water
+Lead	1030	EPA 200.9	23.8	ppb	2.0	20 ppb	08/15/16 16:05 MCLE
6183007-19	Sample Name: F 106 Front North East Sink Sampled: 6/28/16 6:55						Matrix: Water
+Lead	1030	EPA 200.9	80.2	ppb	8.0	20 ppb	08/15/16 16:05 MCLE
6183007-20	Sample Name: F Hallway Tall fountain Sampled: 6/28/16 6:55						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C
L
I
E
N
T
Newberg School District
Attn: Scott Woods
714 E 6th St.
Newberg OR, 97132
Phone: (503) 554-5024

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-21	Sample Name: C 101 Sampled: 6/28/16 7:25		Matrix: Water				
+Lead	1030	EPA 200.9	6.9	ppb	2.0	20 ppb	08/15/16 16:05
6183007-22	Sample Name: Upstairs small fountain Sampled: 6/28/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-23	Sample Name: Upstairs tall fountain Sampled: 6/28/16 7:35		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-24	Sample Name: G 101B Sink Sampled: 6/28/16 7:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-25	Sample Name: G Hallway Small fountain Sampled: 6/28/16 7:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-26	Sample Name: G Hallway tall fountain Sampled: 6/28/16 7:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/15/16 16:05
6183007-27	Sample Name: J 108 S.W. sink Sampled: 6/28/16 7:55		Matrix: Water				
+Lead	1030	EPA 200.9	40.9	ppb	4.0	20 ppb	08/15/16 16:05 MCLE
6183007-28	Sample Name: J 108 S.E. Prep Sink Sampled: 6/28/16 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	15.3	ppb	2.0	20 ppb	08/15/16 16:05
6183007-29	Sample Name: J 108 SW Prep Sink Sampled: 6/28/16 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	19.5	ppb	2.0	20 ppb	08/15/16 16:05
6183007-30	Sample Name: J 108 NW Sink Sampled: 6/28/16 8:01		Matrix: Water				
+Lead	1030	EPA 200.9	11.4	ppb	2.0	20 ppb	08/15/16 16:05



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C
L
I
E
N
T
Newberg School District
Attn: Scott Woods
714 E 6th St.
Newberg OR, 97132
Phone: (503) 554-5024

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6183007-31	Sample Name: NE Tall fountain Sampled: 6/28/16 10:45							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-32	Sample Name: NE Short fountain Sampled: 6/28/16 10:45							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-33	Sample Name: East Cafeteria sink Sampled: 6/28/16 10:50							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-34	Sample Name: West Cafeteria sink Sampled: 6/28/16 10:50							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-35	Sample Name: fountain between Red/Blue hall Sampled: 6/28/16 11:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-36	Sample Name: Blue hall fountain - short Sampled: 6/28/16 11:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-37	Sample Name: Blue hall fountain tall Sampled: 6/28/16 11:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-38	Sample Name: fountain N.W. Corner Sampled: 6/28/16 11:10							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-39	Sample Name: fountain SE Corner Sampled: 6/28/16 11:15							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21	
6183007-41	Sample Name: N.E. Kitchen Sink Sampled: 6/28/16 11:30							Matrix: Water
+Lead	1030	EPA 200.9	20.6	ppb	2.0	20 ppb	08/16/16 17:21 MCLE	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-42	Sample Name: Middle Kitchen hand sink Sampled: 6/28/16 11:30		Matrix: Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	08/16/16 17:21
6183007-43	Sample Name: South Kitchen Prep Sink Sampled: 6/28/16 11:30		Matrix: Water				
+Lead	1030	EPA 200.9	16.0	ppb	2.0	20 ppb	08/16/16 17:21
6183007-44	Sample Name: West Kitchen Prep sink Sampled: 6/28/16 11:35		Matrix: Water				
+Lead	1030	EPA 200.9	32.0	ppb	2.0	20 ppb	08/16/16 17:21 MCL E
6183007-45	Sample Name: Office Conference room Sampled: 6/28/16 11:50		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	08/16/16 17:21
6183007-46	Sample Name: Tall drinking fountain - SEC Sampled: 6/28/16 12:10		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	08/16/16 17:21
6183007-47	Sample Name: Short drinking fountain - SEC Sampled: 6/28/16 12:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-48	Sample Name: Commons sink - SEC Sampled: 6/28/16 12:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-49	Sample Name: Breakroom - SEC Sampled: 6/28/16 12:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-50	Sample Name: Healthroom - SEC Sampled: 6/28/16 12:55		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-51	Sample Name: Cafeteria West sink Sampled: 6/28/16 13:45		Matrix: Water				
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	08/16/16 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-52	Sample Name: Cafeteria East sink Sampled: 6/28/16 13:45		Matrix: Water				
+Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	08/16/16 17:21
6183007-53	Sample Name: Health room Sampled: 6/28/16 13:50		Matrix: Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	08/16/16 17:21
6183007-54	Sample Name: Gym fountain Sampled: 6/28/16 14:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-55	Sample Name: Small fountain across gym Sampled: 6/28/16 14:05		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-56	Sample Name: Tall fountain across gym Sampled: 6/28/16 14:05		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-57	Sample Name: Tall commons fountain Sampled: 6/29/16 5:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-58	Sample Name: Short commons fountain Sampled: 6/29/16 5:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-59	Sample Name: Short upstairs fountain Sampled: 6/29/16 5:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-60	Sample Name: Tall upstairs fountain Sampled: 6/29/16 5:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-61	Sample Name: Staff room Sampled: 6/29/16 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	08/16/16 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-62	Sample Name: Kitchen N.E. Sink - MV Sampled: 6/28/16 9:50		Matrix: Water				
+Lead	1030	EPA 200.9	21.8	ppb	2.0	20 ppb	08/16/16 17:21 MCLE
6183007-63	Sample Name: Kitchen N.W. Sink - MV Sampled: 6/28/16 9:50		Matrix: Water				
+Lead	1030	EPA 200.9	8.9	ppb	2.0	20 ppb	08/16/16 17:21
6183007-64	Sample Name: Kitchen South Sink MV Sampled: 6/28/16 9:55		Matrix: Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	08/16/16 17:21
6183007-65	Sample Name: Kitchen Middle Prep sink Sampled: 6/28/16 9:55		Matrix: Water				
+Lead	1030	EPA 200.9	16.8	ppb	2.0	20 ppb	08/16/16 17:21
6183007-66	Sample Name: Short fountain near 153 MV Sampled: 6/29/16 6:55		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-67	Sample Name: Tall fountain near 153 MV Sampled: 6/29/16 6:55		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/16/16 17:21
6183007-68	Sample Name: Gym fountain MV Sampled: 6/29/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	08/16/16 17:21
6183007-69	Sample Name: Health room MV Sampled: 6/29/16 7:05		Matrix: Water				
+Lead	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	08/16/16 17:21
6183007-70	Sample Name: Sink near 105 MV Sampled: 6/29/16 7:10		Matrix: Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	08/16/16 17:21
6183007-71	Sample Name: fountain near 211 MV Sampled: 6/29/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	6.8	ppb	2.0	20 ppb	08/16/16 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 08/18/2016
Received: 06/29/2016
Sampled By: Ross McLeod
Work Order: 6183007

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : Lead Testing
PWSID # :

Sampling Location: Mountain View

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6183007-72	Sample Name: Fountain by room 111 Sampled: 6/29/16 7:50		Matrix: Water				
†Lead	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	08/17/16 15:50
6183007-73	Sample Name: Sink near 205 Sampled: 6/29/16 7:35		Matrix: Water				
†Lead	1030	EPA 200.9	10.8	ppb	2.0	20 ppb	08/17/16 15:50
6183007-74	Sample Name: Staff room Sampled: 6/29/16 7:40		Matrix: Water				
†Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	08/17/16 15:50

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director