



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 08/29/2016  
Received: 08/25/2016  
Sampled By: Scott Woods  
Work Order: 6238011

**C** **Newberg School District**  
**L** Attn: -  
**I** 714 E 6th St.  
**E** Newberg OR, 97132  
**N** Phone: (503) 554-5024  
**T**

**Project:** Lead Testing  
**Project # :** N/A  
**PWSID # :**

**Sampling Location:** Various - Re-Test  
**Sample Matrix:** Water

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6238011-01</b>	<b>Sample Name:</b> MR - West Kitchen Prep Sink - First Draw <b>Sampled:</b> 8/25/16 7:15						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/26/16 17:49

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

DRAFT REPORT  
DATA SUBJECT TO CHANGE