



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/25/2016
Received: 10/18/2016
Sampled By: Scott Woods
Work Order: 6292003

C **Newberg School District**
L Attn: -
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead - re-test
Project # : N/A
Sample Type :

Sampling Location: Various

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6292003-01	Sample Name: NHS F106 Front N. Sink Sampled: 10/18/16 6:30						Matrix: Water
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	10/21/16 17:04
6292003-02	Sample Name: NHS Gym E. Side Hosebib Sampled: 10/18/16 6:45						Matrix: Water
+Lead	1030	EPA 200.9	14.8	ppb	2.0	20 ppb	10/21/16 17:04
6292003-03	Sample Name: MTV Kettle faucet Sampled: 10/18/16 7:00						Matrix: Water
+Lead	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	10/21/16 17:04
6292003-04	Sample Name: MTV NE Kit. Sink Sampled: 10/18/16 7:05						Matrix: Water
+Lead	1030	EPA 200.9	16.4	ppb	2.0	20 ppb	10/21/16 17:04

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.