



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/26/2016
Received: 10/20/2016
Sampled By: Scott Woods
Work Order: 6294015

**C
L
I
E
N
T**
Newberg School District
Attn: Scott Woods
714 E 6th St.
Newberg OR, 97132
Phone: (503) 554-5024

Project: Lead
Project # : N/A
Sample Type :

Sampling Location: Various

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6294015-01	Sample Name: NHS Tennis Fountain		Matrix: Water				
	Sampled: 10/20/16 6:45						
†Lead	1030	EPA 200.9	17.5	ppb	2.0	20 ppb	10/24/16 16:59
6294015-02	Sample Name: NHS East fountain varsity field		Matrix: Water				
	Sampled: 10/20/16 6:55						
†Lead	1030	EPA 200.9	12.1	ppb	2.0	20 ppb	10/24/16 16:59

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.