



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 08/24/2016  
Received: 08/22/2016  
Sampled By: Scott Woods  
Work Order: 6235003

**C** **Newberg School District**  
**L** Attn: -  
**I** 714 E 6th St.  
**E** Newberg OR, 97132  
**N** Phone: (503) 554-5024  
**T**

**Project:** Lead Testing  
Project # : N/A  
PWSID # :

Sampling Location: Various - Re-test

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6235003-01</b>	<b>Sample Name:</b> NHS J108 SW Sink - First Draw <b>Sampled:</b> 8/22/16 7:00						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	18.8	ppb	2.0	20 ppb	08/22/16 16:38
<b>6235003-02</b>	<b>Sample Name:</b> South Cola Port Sink - First Draw <b>Sampled:</b> 8/22/16 6:45						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	12.3	ppb	2.0	20 ppb	08/23/16 15:46

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director