



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 09/02/2016
Received: 08/29/2016
Sampled By: Scott Woods
Work Order: 6242011

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : N/A
PWSID # :

Sampling Location: Various Re-Test

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6242011-01	Sample Name: NHS F-103 Front East Sink Sampled: 8/29/16 6:50 Sample Composition: 1st Draw						Matrix: Water
†Lead	1030	EPA 200.9	33.7	ppb	2.0	20 ppb	08/31/16 16:41 MCLE
6242011-02	Sample Name: NHS F-106 Front North Sink Sampled: 8/29/16 6:45 Sample Composition: 1st Draw						Matrix: Water
†Lead	1030	EPA 200.9	27.2	ppb	2.0	20 ppb	08/31/16 16:41 MCLE
6242011-03	Sample Name: NHS J-108 SE Prep Sink Sampled: 8/29/16 6:58 Sample Composition: 1st Draw						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	08/31/16 16:41
6242011-04	Sample Name: NHS J-108 SW Prep Sink Sampled: 8/29/16 7:00 Sample Composition: 1st Draw						Matrix: Water
†Lead	1030	EPA 200.9	15.5	ppb	2.0	20 ppb	08/31/16 16:41
6242011-05	Sample Name: MTV Kitchen NE Sink Sampled: 8/29/16 7:18 Sample Composition: 1st Draw						Matrix: Water
†Lead	1030	EPA 200.9	155	ppb	8.0	20 ppb	08/31/16 16:41 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director