



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 09/09/2016  
Received: 09/01/2016  
Sampled By: S. Woods  
Work Order: 6245006

**C** **Newberg School District**  
**L** Attn: -  
**I** 714 E 6th St.  
**E** Newberg OR, 97132  
**N** Phone: (503) 554-5024  
**T**

**Project:** Lead Testing  
Project # : N/A  
PWSID # :

Sampling Location: Various

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6245006-01</b>	<b>Sample Name:</b> MTV - S - outside faucet <b>Sampled:</b> 9/1/16 8:08		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.7	ppb	4.0	20 ppb	09/08/16 17:16
<b>6245006-02</b>	<b>Sample Name:</b> NHS Tennis fountain <b>Sampled:</b> 9/1/16 8:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>36.6</b>	ppb	4.0	20 ppb	09/08/16 17:16 <b>MCLE</b>
<b>6245006-03</b>	<b>Sample Name:</b> NHS - Softball Tall <b>Sampled:</b> 9/1/16 8:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	4.0	20 ppb	09/08/16 17:16
<b>6245006-04</b>	<b>Sample Name:</b> NHS - Softball Short <b>Sampled:</b> 9/1/16 8:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	4.0	20 ppb	09/08/16 17:16
<b>6245006-05</b>	<b>Sample Name:</b> NHS - West fountain baseball <b>Sampled:</b> 9/1/16 8:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9.7	ppb	4.0	20 ppb	09/08/16 17:16
<b>6245006-06</b>	<b>Sample Name:</b> NHS - E - fountain baseball <b>Sampled:</b> 9/1/16 8:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>23.8</b>	ppb	4.0	20 ppb	09/08/16 17:16 <b>MCLE</b>
<b>6245006-07</b>	<b>Sample Name:</b> NHS Gym E side Hose Bib <b>Sampled:</b> 9/1/16 8:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>30.2</b>	ppb	4.0	20 ppb	09/08/16 17:16 <b>MCLE</b>
<b>6245006-08</b>	<b>Sample Name:</b> South Fence Line - NHS <b>Sampled:</b> 9/1/16 8:53		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	4.0	20 ppb	09/08/16 17:16

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.



Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/09/2016  
Received: 09/01/2016  
Sampled By: S. Woods  
Work Order: 6245006

**C** **Newberg School District**  
**L** Attn: -  
**I** 714 E 6th St.  
**E** Newberg OR, 97132  
**N** Phone: (503) 554-5024  
**T**

**Project:** Lead Testing  
Project # : N/A  
PWSID # :

Sampling Location: Various

**Lab Number**

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director