



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/09/2016
Received: 09/01/2016
Sampled By: S. Woods
Work Order: 6245004

C **Newberg School District**
L Attn: -
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Testing
Project # : N/A
PWSID # :

Sampling Location: NHS - Retest

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--|-----------|-------------|-------|-----|----------|----------------------------|
| 6245004-01 | Sample Name: NHS F-103 Front East Sink | | | | | | Matrix: Water |
| | Sampled: 9/1/16 6:45 | | | | | | |
| †Lead | 1030 | EPA 200.9 | ND | ppb | 4.0 | 20 ppb | 09/08/16 17:16 |
| 6245004-02 | Sample Name: NHS F-106 Front North Sink | | | | | | Matrix: Water |
| | Sampled: 9/1/16 6:50 | | | | | | |
| †Lead | 1030 | EPA 200.9 | 38.7 | ppb | 4.0 | 20 ppb | 09/08/16 17:16 MCLE |

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director