



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/15/2016

Received: 09/09/2016

Sampled By: Scott Woods

Work Order: 6253007

C **Newberg School District**
L Attn: Scott Woods
I 714 E 6th St.
E Newberg OR, 97132
N Phone: (503) 554-5024
T

Project: Lead Re-Test

Project # : N/A

PWSID # :

Sampling Location: Mountain View

Sample Matrix: Water

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6253007-01	Sample Name: MTV Kitchen NE Sink						Matrix: Water
	Sampled: 9/9/16 6:43		Sample Composition: 1st Draw				
+Lead	1030	EPA 200.9	38.1	ppb	2.0	20 ppb	09/14/16 15:36 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.