



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 09/26/2016  
Received: 09/20/2016  
Sampled By: S. Woods  
Work Order: 6264018

**C** **Newberg School District**  
**L** Attn: -  
**I** 714 E 6th St.  
**E** Newberg OR, 97132  
**N** Phone: (503) 554-5024  
**T**

**Project:** Lead Testing  
Project # : N/A  
Sample Type :

Sampling Location: NHS  
Sample Matrix: Water

**Lab Number**

| Lab Number        | Code   | Method    | Result | Units | MRL | EPA MCL* | Analysis Date/ Time  |
|-------------------|--|-----------|--------|-------|-----|----------|----------------------|
| <b>6264018-01</b> | <b>Sample Name:</b> NHS SE Prep handwash sink                              |           |        |       |     |          | <b>Matrix:</b> Water |
|                   | <b>Sampled:</b> 9/20/16 6:55 <b>Sample Composition:</b> 1st Draw - Re-test |           |        |       |     |          |                      |
| †Lead             | 1030   | EPA 200.9 | 16.8   | ppb   | 2.0 | 20 ppb   | 09/21/16 16:46       |

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director